

# MIDEL TRANSFORMER RISK REPORT: THE RESULTS

## TRANSFORMER FAILURE SIGNIFICANTLY IMPACTS BUSINESS CONTINUITY

### [ TRANSFORMER FAILURE CAUSES HIGH LEVEL OF CONCERN ]

**>60%**

have experienced transformer failure in the past 5 years

**80%**

are concerned about the impact of transformer failure on business continuity and loss of revenue

**6 in 10**

are concerned by a lack of transformer maintenance

### [ LEVEL OF IMPACT OF A TRANSFORMER FAILURE EVENT ]

**50%**

of businesses' operations would be significantly impacted

**>70%**

of businesses' operations would be disrupted for 3 days+

### [ OPERATORS CAN TAKE CONTROL OF TRANSFORMER FAILURE CAUSES ]

**87%**

of businesses reduce transformer risk by sourcing good quality equipment and components

**76%**

of businesses reduce transformer risk by following a maintenance schedule

### [ THE CHOICE OF TRANSFORMER FLUID MATTERS ]

**61%**

of respondents use biodegradable transformer fluids that protect the environment

Top considerations:

**#1**

Dielectric performance

**#2**

Fire safety

**#3**

Price

MIDEL's Transformer Risk Report aims to enhance understanding of the impact, levels of concern and attitudes towards transformer failure risk mitigation.

Any recommendation or suggestion relating to the use, storage, handling or properties of the products supplied by M&I Materials Ltd or any member of its group, either in sales and technical literature or in response to a specific enquiry or otherwise, is given in good faith but it is for the customer to satisfy itself of the suitability of the product for its own particular purposes and to ensure that the product is used correctly and safely in accordance with the manufacturer's written instructions.